

# X-FLOW HFW 1000 NANOFILTRATION MEMBRANE

## MEMBRANE ELEMENT DATASHEET

8" HFW 1000 PVC 0.8mm  
ARTICLE CODE : 2871FN2MENH

### GENERAL INFORMATION

HFW 1000 is a chlorine tolerant nanofiltration module, used for production of process and potable water. Typical applications are the filtration of surface water, potable water and WWTP effluent for the removal of color components (typically humic or fuming acids), and minimal salt retention. Mode of operation is feed-and-bleed with a crossflow with regular backwash (permeate only) and chemically cleaning.

### GENERAL SOLVENT RESISTANCE

Since the resistance of the membrane to solvents strongly depends on the actual process conditions, the indications given below should only be considered as guideline.

|                                 |    |
|---------------------------------|----|
| Acids                           | ++ |
| Bases                           | ++ |
| Organic esters, ketones, ethers | -  |
| Aliphatic alcohols              | +  |
| Aliphatic hydrocarbons          | +  |
| Halogenated hydrocarbons        | -- |
| Aromatic hydrocarbons           | -- |
| Polar organic solvents          | -- |
| Oils                            | ++ |

### MEMBRANE CHARACTERISTICS

- Hydrophilic membrane composed of modified polyethersulfone and polyethersulfone
- Structure highly asymmetric/microporous
- MWCO: 1000 Da (Dextrane)
- High performance and a very good anti-fouling behaviour
- Provides > 4-log (99,99 percent) reduction of viruses
- Typical permeate quality SDI<3, turbidity <0,1 NTU
- Designed for color removal; typical process retention of > 90% (Pt-Co)
- Minimal salt rejection to maintain salt balance

### CLEANING CHEMICAL RESISTANCE

#### Sodium Hypochlorite

- Typical 200 ppm, at  $\leq 40\text{ }^{\circ}\text{C}$  at  $\geq \text{pH } 10$
- 150.000 ppm hours cumulative; pH 11

The HFW 1000 is able to withstand chemical cleaning with chlorine for entire membrane lifetime according to Pentair's process design.

As a good working practice and in order to maximise the lifetime of the membrane it is advised to reduce the membrane exposure to oxidising agents to a minimum. Exposure limits are also affected by temperature, pH and the presence of metals. In order not to exceed maximum exposure limits, membranes must be preserved free of any oxidising agent when the plant is stopped.

#### Acids

|                   |    |
|-------------------|----|
| Hydrochloric Acid | ++ |
| Nitric Acid       | ++ |
| Sulphuric Acid    | ++ |
| Phosphoric Acid   | ++ |
| Acetic Acid       | ++ |
| Citric Acid       | ++ |

pH > 3 during filtration  
pH > 2 during cleaning


#### Bases

|                           |    |
|---------------------------|----|
| Sodium Hydroxide (<4%)    | ++ |
| Potassium Hydroxide (<4%) | ++ |

pH < 11 during filtration  
pH < 12 during cleaning

### ELEMENT SPECIFICATIONS

| Membrane Diameter [mm/mil] | Membrane area [m <sup>2</sup> /ft <sup>2</sup> ] | Feed connection D <sub>0</sub> [mm/Inch] | Element outer diameter D <sub>1</sub> [mm/Inch] | Element length L <sub>0</sub> [mm/Inch] | Permeate connection d <sub>0</sub> [mm/Inch] |
|----------------------------|--|--|---|---|--|
| 0.8 [31]                   | 40 [430]   | 220.0 [8.66]                             | 200 [7.9]                                       | 1537.5 [60.51]                          | 42.6 [1.68]                                  |



# X-FLOW HFW 1000 NANOFILTRATION MEMBRANE

## MEMBRANE ELEMENT DATASHEET

### OPERATING SPECIFICATIONS

| Max. system pressure | Max. trans-membrane pressure | Max. backflush pressure | Temp. range      |
|----------------------|------------------------------|-------------------------|------------------|
| [kPa/psi]            | [kPa/psi]                    | [kPa/psi]               | [°C/°F]          |
| 700<br>[100]         | 600<br>[86]                  | 600<br>[86]             | 0-40<br>[32-104] |

- Backwash water should be permeate quality or better.
- Backwash pumps should preferably be made of non-corroding materials, e.g., plastic or stainless steel. If compressed air is used to pressurize the backwash water, do not allow a two-phase air/water mixture to enter the element.

- To avoid mechanical damage, do not subject the membrane module or element to sudden temperature changes, particularly decreasing. Bring the module or element back to ambient operating temperature slowly. Failure to adhere to this guideline can result in irreparable damage.

Operation of membrane modules at any combination of maximum limits of pH, concentration, pressure or temperature, during cleaning or production, will influence the membrane lifetime.

### CERTIFICATIONS

- USA: ANSI/NSF, Standard 61
- UK: DWI Regulation 31 (pending)
- The Netherlands: KIWA ATA

France

### TECHNICAL SPECIFICATIONS

#### Weight Specifications

Dry weight of membrane element  
ca. 27 kg [59 lbs]

Membrane element filled with water  
ca. 57 kg [125 lbs]

#### Materials of Construction

Housing: PVC white  
Flow distributor: PES  
Potting: EP resin  
Membrane: PESm/PES

#### Process Characteristics (Water, 20 °C)

| Hydraulic membrane diameter | Crossflow flow rate (*) | Pressure-drop across module at 1 m/s | Pressure-drop across module at 2 m/s |
|-----------------------------|-------------------------|--------------------------------------|--------------------------------------|
| [mm/mil]                    | [m³/h/gpm]              | [kPa/psi]                            | [kPa/psi]                            |
| 0.8 [43]                    | 19.8 x v [26 x v]       | 72 [10]                              | 150 [21]                             |

(\*) superficial velocity (v) in m/s [ft/s]

# X-FLOW HFW 1000 NANOFILTRATION MEMBRANE

## MEMBRANE ELEMENT DATASHEET

---

### STORAGE

---

New membrane modules can be stored as supplied in the original packaging. The membrane elements contain an aqueous preservation solution of glycerine (20wt%) and sodium metabisulfite (1wt%).

Membrane modules should be stored in a dry, normally ventilated place, away from sources of heat, ignition and direct sunlight. Store between 0 and 40 °C.

The membrane modules should not be subjected to any freezing temperatures.

Shelf life is a maximum of 6 months for unused modules in unopened packaging under correct storage conditions after transfer of ownership for X-Flow B.V. to the Client. After the maximum period of 6 months all warranties are null and void unless otherwise agreed in writing between the parties.

After use, the NF membrane modules need to be stored wet at all times. To avoid biological growth during shutdowns or storage, wet membranes could be treated with a compatible biocide. The membrane is compatible with many common disinfecting agents or biocidal preservatives.

Typically for short-term shutdowns (1 – 7 days), a daily backwash with permeate quality water, should be adequate for bacteria control. Before start of the shutdown period, the modules must be cleaned by a standard Chemical Cleaning.

In case of long-term storage (> 7 days), membranes should be chemically cleaned before the disinfection step is carried out. For disinfection, a 0.5% sodium metabisulfite solution can be used. In both short and long term storage situations, the modules should remain filled with storage solution.

Do not use chorine for storage.



#### X-FLOW BV

P.O. BOX 739, 7500 AS ENSCHEDE, NETHERLANDS [WWW.X-FLOW.COM](http://WWW.X-FLOW.COM)

Note: The information and data contained in this document are based on our general experience and are believed to be correct. They are given in good faith and are intended to provide a guideline for the selection and use of our products. Since the conditions under which our products may be used are beyond our control, this information does not imply any guarantee of final product performance and we cannot accept any liability with respect to the use of our products. The quality of our products is guaranteed under our conditions of sale. Existing industrial property rights must be observed.  
DS HFW 1000 EN 1215 © 2015 Pentair. All Rights Reserved.

